

NYC Department of Buildings

ECB Violation Details

Premises: 172 MONTAGUE STREET BROOKLYN Filed At: 172 MONTAGUE STREET , BROOKLYN , NY 11201
 BIN: [3002104](#) Block: 250 Lot: 28 Community Board: 302

ECB Violation Summary

VIOLATION OPEN

ECB Violation Number: 35093003Z

Severity: CLASS - 1

Certification Status: NO COMPLIANCE RECORDED

Hearing Status: PENDING

Penalty Balance Due: \$0.00

Respondent Information

Name: CAVA CONSTRUCTION CO INC
 Mailing Address: 15 SO.MACQUESTEN PARKWAY , MOUNT VERNON , NY 10550
 License/Registration/Tracking Number: [GC583](#)

Violation Details

Violation Date: 05/14/2014 Violation Type: CONSTRUCTION
 Served Date: 05/14/2014 Inspection Unit: BEST SQUAD

Infraction Codes	Section of Law	Standard Description
131	BC 3307.3.1,27-102(A)	FAILURE TO PROVIDE SIDEWALK SHED WHERE REQUIRED

Specific Violation Condition(s) and Remedy:

FAILURE TO PROVIDE SIDEWALK SHED WHERE REQUIRED.NOTE:@ TIME OF INSP.CONSTRUCTION OF A 19 STORY BLDG IN PROGRESS,BLDG WAS BEING CONSTRUCTED ON PROPERTY LINE BLDG WAS APPROX.30'9" IN HEIGHT AN APPROX.5' BACK FROM

Issuing Inspector ID: 2555 DOB Violation Number: 051414BS02BG02
 Issued as Aggravated Level: NO

Dept. of Buildings Compliance Information

Certification Status: NO COMPLIANCE RECORDED
 Compliance On:

A Certificate of Correction must be submitted to the Administrative Enforcement Unit (AEU) for all violations. A violation that is not dismissed by ECB will continue to remain ACTIVE or "open" on DOB records until acceptable proof is submitted to the AEU, even if you have paid the penalty imposed by ECB.

ECB Hearing Information

Scheduled Hearing Date: 06/30/2014 Hearing Status: PENDING
 Hearing Time: 8:30

ECB Penalty Information

Penalty Imposed: \$0.00
 Adjustments: \$0.00
 Amount Paid: \$0.00
 Penalty Balance Due: \$0.00